

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Arapahoe Ridge ES

Sample Type	Sample ID	Sample Description	Lead Result	Action Taken	Back in Service	Sample Count
			in PPB		Date	
Initial Sample	021517.180A.A100DF.01	Drinking fountain, corridor A100, NW corner, right side DF	ND	-	-	1
	021517.180A.A100DF.02	Drinking fountain, corridor A100, NW corner, left side DF	ND	-	-	1
	021517.180A.A101SK.01	Sink, room A101	1.1	-	-	1
	021517.180A.A105DF.01	Drinking fountain, corridor A105, left side DF	ND	-	-	1
	021517.180A.A105DF.02	Drinking fountain, corridor A105, right side DF	ND	-	-	1
	021517.180A.A110SK.01	Sink, room A110, NW corner	0.74	-	-	1
	021517.180A.A110SK.02	Sink, room A110, West wall, kitchen	15	Taken offline	-	1
	021517.180A.A110SK.03	Sink, room A110, SW corner	0.65	-	-	1
	021517.180A.A110SK.04	Sink, room A110, NE corner	0.71	-	-	1
	021517.180A.A113SK.01	Sink, room A113	ND	-	-	1
	021517.180A.A119SK.01	Sink, room A119	ND	-	-	1
	021517.180A.A122SK.01	Sink, room A122	ND	-	-	1
	021517.180A.A203SK.01	Sink, room A203	ND	-	-	1
	021517.180A.B100.1DF.01	Drinking fountain, corridor B100.1, north wall, left side DF	ND	-	-	1
	021517.180A.B100.1DF.02	Drinking fountain, corridor B100.1, north wall, right side DF	ND	-	-	1
	021517.180A.B100DF.01	Drinking fountain, corridor B100, south wall, right side DF	ND	-	-	1
	021517.180A.B100DF.02	Drinking fountain, corridor B100, south wall, left side DF	ND	-	-	1
	021517.180A.B103SK.01	Sink, room B103	0.66	-	-	1
	021517.180A.B104DF.01	Drinking fountain, room B104, attached to sink	ND	-	-	1
	021517.180A.B104SK.01	Sink, room B104	ND	-	-	1
	021517.180A.B106DF.01	Drinking fountain, room B106	0.77	-	-	1
	021517.180A.B106SK.01	Sink, room B106	ND	-	-	1
	021517.180A.B112DF.01	Drinking fountain, room B112	0.5	-	-	1
	021517.180A.B112SK.01	Sink, room B112	ND	-	-	1
	021517.180A.B123DF.01	Drinking fountain, room B123	1.4	-	-	1
	021517.180A.B123SK.01	Sink, room B123	2.1	-	-	1
	021517.180A.B129DF.01	Drinking fountain, room B129	0.78	-	-	1
	021517.180A.B129SK.01	Sink, room B129	0.73	-	-	1
	021517.180A.B130SK.01	Sink, room B130, west wall, south sink	0.74	-	-	1
	021517.180A.B130SK.02	Sink, room B130, west wall, north sink	0.59	-	-	1
	021517.180A.B200DF.01	Drinking fountain, corridor B200, south wall, right side DF	ND	-	-	1
	021517.180A.B200DF.02	Drinking fountain, corridor B200, south wall, left side DF	ND	-	-	1
	021517.180A.B206SK.01	Sink, room B206	0.74	-	-	1
	021517.180A.B213SK.01	Sink, room B213	1.2	-	-	1
	021517.180A.B214SK.01	Sink, room B214	0.86	-	-	1
	021517.180A.B215SK.01	Sink, room B215	0.6	-	-	1
	021517.180A.B216SK.01	Sink, room B216	1	-	-	1
	021517.180A.B217SK.01	Sink, room B217	1	-	-	1
	021517.180A.B218SK.01	Sink, room B218	1.3	-	-	1
	021517.180A.B219SK.01	Sink, room B219	1.2	-	-	1
	021517.180A.B220SK.01	Sink, room B220	0.85	-	-	1
	021517.180A.B221SK.01	Sink, room B221	0.77	-	-	1
	021517.180A.B222SK.01	Sink, room B222	1.3	-	-	1
	021517.180A.C106SK.01	Sink, room C106	1	-	-	1
Initial Sample Total						44
Re-test Sample	041117.180A.A110SK.02	Sink, room A110, West wall, kitchen	1.3	-	4/27/2017	1
Re-test Sample Total						1