

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **BTEC**

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
Initial Sample	042917.410A.117SK.01	Sink, room 117	1.8	-	-	1
	042917.410A.123DF.01	Drinking fountain, hallway 123, north wall, left side DF	3.5	-	-	1
	042917.410A.123DF.02	Drinking fountain, hallway 123, north wall, right side DF	1.5	-	-	1
	042917.410A.128SK.01	Sink, room 128, south wall	1.1	-	-	1
	042917.410A.128SK.02	Sink, room 128, north wall	2.6	-	-	1
	042917.410A.128SK.03	Sink, room 128, west wall	2.9	-	-	1
	042917.410A.132SK.01	Sink, room 132	2.8	-	-	1
	042917.410A.205SK.01	Sink, room 205	1	-	-	1
	042917.410A.239DF.01	Drinking fountain, corridor 239	0.83	-	-	1
	042917.410A.302SK.01	Sink, room 302, left side sink	9.3	-	-	1
	042917.410A.302SK.02	Sink, room 302, middle sink	5	-	-	1
	042917.410A.302SK.03	Sink, room 302, right side sink	9.3	-	-	1
	042917.410A.312SK.01	Sink, room 312, left side sink	6.3	-	-	1
	042917.410A.312SK.02	Sink, room 312, right side sink	5.4	-	-	1
	042917.410A.402SK.01	Sink, room 402, currently engineering classroom	16	Taken offline	-	1
	042917.410A.414DF.01	Drinking fountain, room 414	0.89	-	-	1
	042917.410A.415DF.01	Drinking fountain, room 415	4.8	-	-	1
042917.410A.415SK.01	Sink, room 415	1.7	-	-	1	
042917.410A.422SK.01	Sink, room 422	9.2	-	-	1	
Initial Sample Total						19
Re-test Sample - 1	071217.410A.402SK.01	Sink, room 402, currently engineering classroom	5	Back in service	7/12/2017	1
Re-test Sample - 1 Total						1