

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Centennial ES

Sample ID	Sample Description	Lead Result	
		in PPB	Action Taken
012517.101A.H8DF.01	Drinking fountain, hallway H6, east end, N wall	5.9	-
012517.101A.H8DF.02	Drinking fountain, hallway H6, west end, N wall	1.1	-
012517.101A.30SK.01	Sink, room 30	11	-
012517.101A.49SK.01	Sink, room 49	3.4	-
012517.101A.50SK.01	Sink, room 50	3.1	-
012517.101A.44SK.01	Sink, room 44	11	-
012517.101A.44DF.01	Drinking fountain, room 44	2.7	-
012517.101A.45SK.01	Sink, room 45	8.7	-
012517.101A.45DF.01	Drinking fountain, room 45	2	-
012517.101A.46SK.01	Sink, room 46	12	-
012517.101A.46DF.01	Drinking fountain, room 46	7.5	-
012517.101A.47SK.01	Sink, room 47, currently ELL class	18	Taken Offline
012517.101A.47DF.01	Drinking fountain, room 47	3.2	-
012517.101A.51SK.01	Sink, room 51	11	-
012517.101A.51DF.01	Drinking fountain, room 51	2.7	-
012517.101A.52SK.01	Sink, room 52	4.8	-
012517.101A.52DF.01	Drinking fountain, room 52, currently 3rd grade class	15	Taken Offline
012517.101A.62SK.01	Sink, room 62	8.6	-
012517.101A.62DF.01	Drinking fountain, room 62	2	-
012517.101A.58SK.01	Sink, room 58	4.5	-
012517.101A.54SK.01	Sink, room 54	8.2	-
012517.101A.54DF.01	Drinking fountain, room 54	2.1	-
012517.101A.37SK.01	Sink, room 37	12	-
012517.101A.37DF.01	Drinking fountain, room 37	3.1	-
012517.101A.38SK.01	Sink, room 38	14	-
012517.101A.38DF.01	Drinking fountain, room 38	4.2	-
012517.101A.42SK.01	Sink, room 42, currently 2nd grade class	15	Taken Offline
012517.101A.42DF.01	Drinking fountain, room 42	2.9	-
012517.101A.43SK.01	Sink, room 43, currently computer lab	39	Taken Offline
012517.101A.43DF.01	Drinking fountain, room 43	6.8	-
012517.101A.35SK.01	Sink, room 35	5.8	-
012517.101A.35DF.01	Drinking fountain, room 35	6.4	-
012517.101A.36SK.01	Sink, room 36	7.6	-
012517.101A.36DF.01	Drinking fountain, room 36	0.77	-
012517.101A.40SK.01	Sink, room 40, currently 3rd grade class	28	Taken Offline
012517.101A.40DF.01	Drinking fountain, room 40	1.2	-
012517.101A.41SK.01	Sink, room 41, currently book storage and reading room	40	Taken Offline
012517.101A.41DF.01	Drinking fountain, room 41	4.2	-
012517.101A.69SK.01	Sink, room 69, east wall, north sink	2.6	-
012517.101A.69SK.02	Sink, room 69, east wall, middle sink	1.6	-
012517.101A.69SK.03	Sink, room 69, east wall, south sink	2.8	-
012517.101A.68SK.01	Sink, room 68, currently 4th grade class	47	Taken Offline

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Centennial ES**

<u>Sample ID</u>	<u>Sample Description</u>	<u>Lead Result</u> <u>in</u> <u>PPB</u>	<u>Action Taken</u>
012517.101A.68DF.01	Drinking fountain, room 68	2.8 -	
012517.101A.73SK.01	Sink, room 73	12 -	
012517.101A.73DF.01	Drinking fountain, room 73	3.8 -	
012517.101A.74SK.01	Sink, room 74	4.6 -	
012517.101A.74DF.01	Drinking fountain, room 74	5.2 -	
012517.101A.66SK.01	Sink, room 66	3.8 -	
012517.101A.66DF.01	Drinking fountain, room 66	2.2 -	
012517.101A.67SK.01	Sink, room 67	11 -	
012517.101A.67DF.01	Drinking fountain, room 67	2.6 -	
012517.101A.71SK.01	Sink, room 71	6.8 -	
012517.101A.71DF.01	Drinking fountain, room 71	6 -	
012517.101A.72SK.01	Sink, room 72, currently 5th grade class	30	Taken Offline
012517.101A.72DF.01	Drinking fountain, room 72	3.3 -	
012517.101A.26SK.01	Sink, room 26	3.6 -	
012517.101A.21SK.01	Sink, room 21	1.2 -	
012517.101A.18SK.01	Sink, room 18, south wall, west sink	3.4 -	
012517.101A.18DF.01	Drinking fountain, room 18, next to SK.01	7.4 -	
012517.101A.18SK.02	Sink, room 18, south wall, east sink, cafeteria	16	Taken Offline
012517.101A.18DF.02	Drinking fountain, room 18, next to SK.02	13 -	
012517.101A.14SK.01	Sink, room 14, north wall, west side	4 -	
012517.101A.14SK.02	Sink, room 14, north wall, middle	4.6 -	
012517.101A.14SK.03	Sink, room 14, NE corner	4.8 -	
012517.101A.14SK.04	Sink, room 14, SE corner	2.7 -	

Resultados de las Muestras de Agua

Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

Action = Acción

Taken offline = Desconectado/a