

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Cotton Creek ES**

Sample Type	Sample ID	Sample Description	Lead Result	Action Taken	Back in Service	Sample Count
			in PPB		Date	
Initial Sample	013117.111A.11DF.01	Drinking fountain, room 11	8.1	-	-	1
	013117.111A.11SK.01	Sink, room 11, currently the library	16	Taken offline	-	1
	013117.111A.12SK.01	Sink, room 12	2.2	-	-	1
	013117.111A.14SK.01	Sink, room 14, north wall	1.1	-	-	1
	013117.111A.14SK.02	Sink, room 14, NE corner	5.7	-	-	1
	013117.111A.14SK.03	Sink, room 14, SE corner	4.8	-	-	1
	013117.111A.14SK.04	Sink, room 14, south wall	1.9	-	-	1
	013117.111A.18DF.01	Drinking fountain, room 18	3.2	-	-	1
	013117.111A.18SK.01	Sink, room 18, NE sink	1.3	-	-	1
	013117.111A.18SK.02	Sink, room 14, SE sink	0.73	-	-	1
	013117.111A.19BSK.01	Sink, room 19B	6.1	-	-	1
	013117.111A.1SK.01	Sink, room 1	1.8	-	-	1
	013117.111A.5SK.01	Sink, room 5	0.94	-	-	1
	013117.111A.7SK.01	Sink, room 7	2.4	-	-	1
	013117.111A.8SK.01	Sink, room 8	3	-	-	1
	013117.111A.AADF.01	Drinking fountain, room AA	4.5	-	-	1
	013117.111A.AASK.01	Sink, room AA	3.2	-	-	1
	013117.111A.ADF.01	Drinking fountain, room A	2.5	-	-	1
	013117.111A.ASK.01	Sink, room A	3.1	-	-	1
	013117.111A.BBDF.01	Drinking fountain, room BB	2.8	-	-	1
	013117.111A.BBSK.01	Sink, room BB	3.9	-	-	1
	013117.111A.BDF.01	Drinking fountain, room B	1.4	-	-	1
	013117.111A.BSK.01	Sink, room B	3.2	-	-	1
	013117.111A.CDF.01	Drinking fountain, room C	0.83	-	-	1
	013117.111A.CSK.01	Sink, room C	3.4	-	-	1
	013117.111A.DDF.01	Drinking fountain, room D	2	-	-	1
	013117.111A.DSK.01	Sink, room D	8.1	-	-	1
	013117.111A.FDF.01	Drinking fountain, room F	5.4	-	-	1
	013117.111A.FSK.01	Sink, room F	2	-	-	1
	013117.111A.GDF.01	Drinking fountain, room G	1.9	-	-	1
	013117.111A.GSK.01	Sink, room G	0.71	-	-	1
	013117.111A.H1DF.01	Drinking fountain, hallway H1, S end, W wall, S DF	ND	-	-	1
	013117.111A.H1DF.02	Drinking fountain, hallway H1, S end, W wall, N DF	ND	-	-	1
	013117.111A.HDF.01	Drinking fountain, room H	1.3	-	-	1
	013117.111A.HSK.01	Sink, room H	2.2	-	-	1
	013117.111A.IDF.01	Drinking fountain, room I	5.2	-	-	1
	013117.111A.ISK.01	Sink, room I	3.9	-	-	1
	013117.111A.JDF.01	Drinking fountain, room J	2.9	-	-	1
	013117.111A.JSK.01	Sink, room J	2.1	-	-	1
	013117.111A.KDF.01	Drinking fountain, room K	3	-	-	1
	013117.111A.KSK.01	Sink, room K	7.4	-	-	1
	013117.111A.LDF.01	Drinking fountain, room L	2.6	-	-	1
	013117.111A.LSK.01	Sink, room L	4.8	-	-	1
	013117.111A.MSDF.01	Drinking fountain, room M	1.6	-	-	1
	013117.111A.MSK.01	Sink, room M	4.3	-	-	1
	013117.111A.NDF.01	Drinking fountain, room N	1.5	-	-	1
	013117.111A.NSK.01	Sink, room N	4.6	-	-	1
013117.111A.PDF.01	Drinking fountain, room P	2.1	-	-	1	
013117.111A.PSK.01	Sink, room P	4.3	-	-	1	
013117.111A.QDF.01	Drinking fountain, room Q	1.2	-	-	1	
013117.111A.QSK.01	Sink, room Q	4	-	-	1	
013117.111A.RDF.01	Drinking fountain, room R	1.3	-	-	1	
013117.111A.RSK.01	Sink, room R	6.2	-	-	1	
013117.111A.SDF.01	Drinking fountain, room S	1.4	-	-	1	
013117.111A.SSK.01	Sink, room S	2	-	-	1	
013117.111A.TDF.01	Drinking fountain, room T	2.5	-	-	1	
013117.111A.TSK.01	Sink, room T	3.8	-	-	1	

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Cotton Creek ES**

<u>Sample Type</u>	<u>Sample ID</u>	<u>Sample Description</u>	<u>Lead Result</u> <u>in</u> <u>PPB</u>	<u>Action Taken</u>	<u>Back in Service</u> <u>Date</u>	<u>Sample</u> <u>Count</u>
Initial Sample	013117.111A.UDF.01	Drinking fountain, room U	1.4	-	-	1
	013117.111A.USK.01	Sink, room U	3.3	-	-	1
	013117.111A.VDF.01	Drinking fountain, room V	2	-	-	1
	013117.111A.VSK.01	Sink, room V	1.8	-	-	1
	013117.111A.WDF.01	Drinking fountain, room W	1.5	-	-	1
	013117.111A.WSK.01	Sink, room W	2.9	-	-	1
	013117.111A.XDF.01	Drinking fountain, room X	1.9	-	-	1
	013117.111A.XSK.01	Sink, room X	1.7	-	-	1
	013117.111A.YDF.01	Drinking fountain, room Y	1.6	-	-	1
	013117.111A.YSK.01	Sink, room Y	2.2	-	-	1
	013117.111A.ZDF.01	Drinking fountain, room Z	2	-	-	1
	013117.111A.ZSK.01	Sink, room Z	1.8	-	-	1
Initial Sample Total						69
Retest Sample - 1	041117.111A.11SK.01	Sink, room 11, currently the library	4.9	Back in service	4/27/2017	1
Retest Sample - 1 Total						1