

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Cotton Creek ES**

<u>Sample ID</u>	<u>Sample Description</u>	<u>Lead Result</u> in <u>PPB</u>	<u>Action Taken</u>
013117.111A.8SK.01	Sink, room 8	3 -	
013117.111A.1SK.01	Sink, room 1	1.8 -	
013117.111A.5SK.01	Sink, room 5	0.94 -	
013117.111A.7SK.01	Sink, room 7	2.4 -	
013117.111A.14SK.01	Sink, room 14, north wall	1.1 -	
013117.111A.14SK.02	Sink, room 14, NE corner	5.7 -	
013117.111A.14SK.03	Sink, room 14, SE corner	4.8 -	
013117.111A.14SK.04	Sink, room 14, south wall	1.9 -	
013117.111A.18SK.01	Sink, room 18, NE sink	1.3 -	
013117.111A.18SK.02	Sink, room 14, SE sink	0.73 -	
013117.111A.18DF.01	Drinking fountain, room 18	3.2 -	
013117.111A.NSK.01	Sink, room N	4.6 -	
013117.111A.NDF.01	Drinking fountain, room N	1.5 -	
013117.111A.PSK.01	Sink, room P	4.3 -	
013117.111A.PDF.01	Drinking fountain, room P	2.1 -	
013117.111A.QSK.01	Sink, room Q	4 -	
013117.111A.QDF.01	Drinking fountain, room Q	1.2 -	
013117.111A.RSK.01	Sink, room R	6.2 -	
013117.111A.RDF.01	Drinking fountain, room R	1.3 -	
013117.111A.SSK.01	Sink, room S	2 -	
013117.111A.SDF.01	Drinking fountain, room S	1.4 -	
013117.111A.TSK.01	Sink, room T	3.8 -	
013117.111A.TDF.01	Drinking fountain, room T	2.5 -	
013117.111A.USK.01	Sink, room U	3.3 -	
013117.111A.UDF.01	Drinking fountain, room U	1.4 -	
013117.111A.VSK.01	Sink, room V	1.8 -	
013117.111A.VDF.01	Drinking fountain, room V	2 -	
013117.111A.WSK.01	Sink, room W	2.9 -	
013117.111A.WDF.01	Drinking fountain, room W	1.5 -	
013117.111A.XSK.01	Sink, room X	1.7 -	
013117.111A.XDF.01	Drinking fountain, room X	1.9 -	
013117.111A.YSK.01	Sink, room Y	2.2 -	
013117.111A.YDF.01	Drinking fountain, room Y	1.6 -	
013117.111A.ZSK.01	Sink, room Z	1.8 -	
013117.111A.ZDF.01	Drinking fountain, room Z	2 -	
013117.111A.KSK.01	Sink, room K	7.4 -	
013117.111A.KDF.01	Drinking fountain, room K	3 -	
013117.111A.ASK.01	Sink, room A	3.1 -	
013117.111A.ADF.01	Drinking fountain, room A	2.5 -	
013117.111A.BSK.01	Sink, room B	3.2 -	

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Cotton Creek ES**

<u>Sample ID</u>	<u>Sample Description</u>	<u>Lead Result</u> in <u>PPB</u>	<u>Action Taken</u>
013117.111A.BDF.01	Drinking fountain, room B	1.4 -	
013117.111A.AASK.01	Sink, room AA	3.2 -	
013117.111A.AADF.01	Drinking fountain, room AA	4.5 -	
013117.111A.BBSK.01	Sink, room BB	3.9 -	
013117.111A.BBDF.01	Drinking fountain, room BB	2.8 -	
013117.111A.CSK.01	Sink, room C	3.4 -	
013117.111A.CDF.01	Drinking fountain, room C	0.83 -	
013117.111A.DSK.01	Sink, room D	8.1 -	
013117.111A.DDF.01	Drinking fountain, room D	2 -	
013117.111A.FSK.01	Sink, room F	2 -	
013117.111A.FDF.01	Drinking fountain, room F	5.4 -	
013117.111A.GSK.01	Sink, room G	0.71 -	
013117.111A.GDF.01	Drinking fountain, room G	1.9 -	
013117.111A.HSK.01	Sink, room H	2.2 -	
013117.111A.HDF.01	Drinking fountain, room H	1.3 -	
013117.111A.ISK.01	Sink, room I	3.9 -	
013117.111A.IDF.01	Drinking fountain, room I	5.2 -	
013117.111A.JSK.01	Sink, room J	2.1 -	
013117.111A.JDF.01	Drinking fountain, room J	2.9 -	
013117.111A.19BSK.01	Sink, room 19B	6.1 -	
013117.111A.H1DF.01	Drinking fopuntain, hallway H1, S end, W wall, S DF	ND	-
013117.111A.H1DF.02	Drinking fopuntain, hallway H1, S end, W wall, N DF	ND	-
013117.111A.12SK.01	Sink, room 12	2.2 -	
013117.111A.11SK.01	Sink, room 11, currently the library	16	Taken Offline
013117.111A.11DF.01	Drinking fountain, room 11	8.1 -	
013117.111A.LSK.01	Sink, room L	4.8 -	
013117.111A.LDF.01	Drinking fountain, room L	2.6 -	
013117.111A.MSK.01	Sink, room M	4.3 -	
013117.111A.MSDF.01	Drinking fountain, room M	1.6 -	

Resultados de las Muestras de Agua

Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

Action = Acción

Taken offline = Desconectado/a