

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Hunters Glen ES**

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
Initial Sample	020817.124A.100SK.01	Sink, room 100	0.53	-	-	1
	020817.124A.101SK.01	Sink, room 101	0.68	-	-	1
	020817.124A.102SK.01	Sink, room 102	6.1	-	-	1
	020817.124A.103SK.01	Sink, room 103	2.7	-	-	1
	020817.124A.105ASK.01	Sink, room 105A	3.3	-	-	1
	020817.124A.106SK.01	Sink, room 106, west wall, middle of room	2.7	-	-	1
	020817.124A.106SK.02	Sink, room 106, west wall, north end of room	3.5	-	-	1
	020817.124A.106SK.03	Sink, room 106, east wall, north end of room	1.4	-	-	1
	020817.124A.106SK.04	Sink, room 106, east wall, middle of room	3.5	-	-	1
	020817.124A.107SK.01	Sink, room 107	ND	-	-	1
	020817.124A.108ASK.01	Sink, room 108A	14	-	-	1
	020817.124A.108DF.01	Drinking fountain, room 108, north end, east wall, right side	2.5	-	-	1
	020817.124A.108DF.02	Drinking fountain, room 108, north end, east wall, left side	1.9	-	-	1
	020817.124A.116DF.01	Drinking fountain, hallway 116, south wall, west DF	ND	-	-	1
	020817.124A.116DF.02	Drinking fountain, hallway 116, south wall, east DF	ND	-	-	1
	020817.124A.AADF.01	Drinking fountain, room AA, attached to sink	ND	-	-	1
	020817.124A.AASK.01	Sink, room AA	1.9	-	-	1
	020817.124A.ABDF.01	Drinking fountain, room AB, attached to sink	2.4	-	-	1
	020817.124A.ABSK.01	Sink, room AB	2.6	-	-	1
	020817.124A.ADF.01	Drinking fountain, room A, attached to sink	2.1	-	-	1
	020817.124A.ASK.01	Sink, room A	6.5	-	-	1
	020817.124A.BBDF.01	Drinking fountain, room BB, attached to sink	0.76	-	-	1
	020817.124A.BBSK.01	Sink, room BB	1.7	-	-	1
	020817.124A.BSK.01	Sink, room B	1	-	-	1
	020817.124A.CDF.01	Drinking fountain, room C, attached to sink	1.2	-	-	1
	020817.124A.CSK.01	Sink, room C	1.4	-	-	1
	020817.124A.DDF.01	Drinking fountain, room D, attached to sink	0.51	-	-	1
	020817.124A.DSK.01	Sink, room D	1.1	-	-	1
	020817.124A.EDF.01	Drinking fountain, room E, attached to sink	1.2	-	-	1
	020817.124A.ESK.01	Sink, room E	2.3	-	-	1
	020817.124A.FDF.01	Drinking fountain, room F, attached to sink	1.7	-	-	1
	020817.124A.FSK.01	Sink, room F	1.4	-	-	1
	020817.124A.GDF.01	Drinking fountain, room G, attached to sink	1.4	-	-	1
	020817.124A.GSK.01	Sink, room G	0.62	-	-	1
	020817.124A.HDF.01	Drinking fountain, room H, attached to sink	1.2	-	-	1
	020817.124A.HSK.01	Sink, room H	1.5	-	-	1
	020817.124A.IDF.01	Drinking fountain, room I, attached to sink	0.66	-	-	1
	020817.124A.ISK.01	Sink, room I	1.7	-	-	1
	020817.124A.KDF.01	Drinking fountain, room K, attached to sink	2	-	-	1
	020817.124A.KSK.01	Sink, room K	2.1	-	-	1
	020817.124A.LSK.01	Sink, room L	1.1	-	-	1
	020817.124A.MDF.01	Drinking fountain, room M, attached to sink	12	-	-	1
	020817.124A.MSK.01	Sink, room M	2.2	-	-	1
	020817.124A.ODF.01	Drinking fountain, room O, attached to sink	1.1	-	-	1
	020817.124A.OSK.01	Sink, room O	2.2	-	-	1
	020817.124A.PDF.01	Drinking fountain, room P, attached to sink	0.76	-	-	1
	020817.124A.PSK.01	Sink, room P	2	-	-	1
	020817.124A.QDF.01	Drinking fountain, room Q, attached to sink	0.91	-	-	1
	020817.124A.QSK.01	Sink, room Q	1.9	-	-	1
	020817.124A.RSK.01	Sink, room R, computer lab	36	Taken offline	-	1
020817.124A.SDF.01	Drinking fountain, room S, attached to sink	0.67	-	-	1	
020817.124A.SSK.01	Sink, room S	1.5	-	-	1	
020817.124A.TDF.01	Drinking fountain, room T, attached to sink	0.64	-	-	1	
020817.124A.TSK.01	Sink, room T	0.74	-	-	1	
020817.124A.UDF.01	Drinking fountain, room U, attached to sink	1.2	-	-	1	
020817.124A.USK.01	Sink, room U	1.4	-	-	1	
020817.124A.VSK.01	Sink, room V	ND	-	-	1	

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Hunters Glen ES**

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
Initial Sample	020817.124A.WDF.01	Drinking fountain, room W, attached to sink	6	-	-	1
	020817.124A.WSK.01	Sink, room W	12	-	-	1
	020817.124A.XDF.01	Drinking fountain, room X, attached to sink	ND	-	-	1
	020817.124A.XSK.01	Sink, room X	1.2	-	-	1
	020817.124A.YDF.01	Drinking fountain, room Y, attached to sink	1.3	-	-	1
	020817.124A.YSK.01	Sink, room Y	0.94	-	-	1
	030717.124A.RDF.01	Drinking fountain, room R, attached to sink	2.5	-	-	1
Initial Sample Total						64
Retest Sample - 1	030717.124A.RSK.01	Sink, room R, computer lab	70	Pending	-	1
Retest Sample - 1 Total						1
Retest Sample - 2	041117.124A.RSK.01	Sink, room R, computer lab	10	Back in service	4/27/2017	1
Retest Sample - 2 Total						1