

## Water Sampling Results

### Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above  
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

**School Name**                      **Hunters Glen ES**

| Sample ID             | Sample Description   | Lead Result<br>in<br>PPB | Action Taken |
|-----------------------|--|--------------------------|--------------|
| 020817.124A.116DF.01  | Drinking fountain, hallway 116, south wall, west DF              | ND                       | -            |
| 020817.124A.116DF.02  | Drinking fountain, hallway 116, south wall, east DF              | ND                       | -            |
| 020817.124A.100SK.01  | Sink, room 100   | 0.53                     | -            |
| 020817.124A.101SK.01  | Sink, room 101   | 0.68                     | -            |
| 020817.124A.102SK.01  | Sink, room 102   | 6.1                      | -            |
| 020817.124A.103SK.01  | Sink, room 103   | 2.7                      | -            |
| 020817.124A.107SK.01  | Sink, room 107   | ND                       | -            |
| 020817.124A.106SK.01  | Sink, room 106, west wall, middle of room                        | 2.7                      | -            |
| 020817.124A.106SK.02  | Sink, room 106, west wall, north end of room                     | 3.5                      | -            |
| 020817.124A.106SK.03  | Sink, room 106, east wall, north end of room                     | 1.4                      | -            |
| 020817.124A.106SK.04  | Sink, room 106, east wall, middle of room                        | 3.5                      | -            |
| 020817.124A.108DF.01  | Drinking fountain, room 108, north end, east wall, right side DF | 2.5                      | -            |
| 020817.124A.108DF.02  | Drinking fountain, room 108, north end, east wall, left side DF  | 1.9                      | -            |
| 020817.124A.108ASK.01 | Sink, room 108A  | 14                       | -            |
| 020817.124A.105ASK.01 | Sink, room 105A  | 3.3                      | -            |
| 020817.124A.ASK.01    | Sink, room A   | 6.5                      | -            |
| 020817.124A.ADF.01    | Drinking fountain, room A, attached to sink                      | 2.1                      | -            |
| 020817.124A.BSK.01    | Sink, room B   | 1                        | -            |
| 020817.124A.AASK.01   | Sink, room AA  | 1.9                      | -            |
| 020817.124A.AADF.01   | Drinking fountain, room AA, attached to sink                     | ND                       | -            |
| 020817.124A.BBSK.01   | Sink, room BB  | 1.7                      | -            |
| 020817.124A.BBDF.01   | Drinking fountain, room BB, attached to sink                     | 0.76                     | -            |
| 020817.124A.ABSK.01   | Sink, room AB  | 2.6                      | -            |
| 020817.124A.ABDF.01   | Drinking fountain, room AB, attached to sink                     | 2.4                      | -            |
| 020817.124A.CSK.01    | Sink, room C   | 1.4                      | -            |
| 020817.124A.DSK.01    | Sink, room D   | 1.1                      | -            |
| 020817.124A.DDF.01    | Drinking fountain, room D, attached to sink                      | 0.51                     | -            |
| 020817.124A.ESK.01    | Sink, room E   | 2.3                      | -            |
| 020817.124A.EDF.01    | Drinking fountain, room E, attached to sink                      | 1.2                      | -            |
| 020817.124A.FSK.01    | Sink, room F   | 1.4                      | -            |
| 020817.124A.FDF.01    | Drinking fountain, room F, attached to sink                      | 1.7                      | -            |
| 020817.124A.GSK.01    | Sink, room G   | 0.62                     | -            |
| 020817.124A.GDF.01    | Drinking fountain, room G, attached to sink                      | 1.4                      | -            |
| 020817.124A.HSK.01    | Sink, room H   | 1.5                      | -            |
| 020817.124A.HDF.01    | Drinking fountain, room H, attached to sink                      | 1.2                      | -            |
| 020817.124A.ISK.01    | Sink, room I   | 1.7                      | -            |
| 020817.124A.IDF.01    | Drinking fountain, room I, attached to sink                      | 0.66                     | -            |
| 020817.124A.KSK.01    | Sink, room K   | 2.1                      | -            |
| 020817.124A.KDF.01    | Drinking fountain, room K, attached to sink                      | 2                        | -            |
| 020817.124A.LSK.01    | Sink, room L   | 1.1                      | -            |
| 020817.124A.CDF.01    | Drinking fountain, room C, attached to sink                      | 1.2                      | -            |
| 020817.124A.MSK.01    | Sink, room M   | 2.2                      | -            |

## Water Sampling Results

### Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

**School Name**                      **Hunters Glen ES**

| <u>Sample ID</u>   | <u>Sample Description</u>                                     | <u>Lead Result</u><br><u>in</u><br><u>PPB</u> | <u>Action Taken</u> |
|--------------------|---|---|---------------------|
| 020817.124A.MDF.01 | Drinking fountain, room M, attached to sink                   | 12 -  |                     |
| 020817.124A.OSK.01 | Sink, room O  | 2.2 -   |                     |
| 020817.124A.ODF.01 | Drinking fountain, room O, attached to sink                   | 1.1 -   |                     |
| 020817.124A.PSK.01 | Sink, room P  | 2 -   |                     |
| 020817.124A.PDF.01 | Drinking fountain, room P, attached to sink                   | 0.76 -  |                     |
| 020817.124A.QSK.01 | Sink, room Q  | 1.9 -   |                     |
| 020817.124A.QDF.01 | Drinking fountain, room Q, attached to sink                   | 0.91 -  |                     |
| 020817.124A.RSK.01 | Sink, room R, computer lab, attached drinking fountain not wo | 36  | Taken Offline       |
| 020817.124A.SSK.01 | Sink, room S  | 1.5 -   |                     |
| 020817.124A.SDF.01 | Drinking fountain, room S, attached to sink                   | 0.67 -  |                     |
| 020817.124A.TSK.01 | Sink, room T  | 0.74 -  |                     |
| 020817.124A.TDF.01 | Drinking fountain, room T, attached to sink                   | 0.64 -  |                     |
| 020817.124A.USK.01 | Sink, room U  | 1.4 -   |                     |
| 020817.124A.UDF.01 | Drinking fountain, room U, attached to sink                   | 1.2 -   |                     |
| 020817.124A.VSK.01 | Sink, room V  | ND  | -                   |
| 020817.124A.WSK.01 | Sink, room W  | 12 -  |                     |
| 020817.124A.WDF.01 | Drinking fountain, room W, attached to sink                   | 6 -   |                     |
| 020817.124A.XSK.01 | Sink, room X  | 1.2 -   |                     |
| 020817.124A.XDF.01 | Drinking fountain, room X, attached to sink                   | ND  | -                   |
| 020817.124A.YSK.01 | Sink, room Y  | 0.94 -  |                     |
| 020817.124A.YDF.01 | Drinking fountain, room Y, attached to sink                   | 1.3 -   |                     |

# Resultados de las Muestras de Agua

## Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

### Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

### Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

### Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

### Action = Acción

Taken offline = Desconectado/a