

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Legacy HS

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
Initial Sample	042717.370A.A102SK.01	Sink, room A102	ND	-	-	1
	042717.370A.A108SK.01	Sink, room A108	0.72	-	-	1
	042717.370A.A113SK.01	Sink, room A113	6	-	-	1
	042717.370A.A118SK.01	Sink, room A118	1.2	-	-	1
	042717.370A.A139DF.01	Drinking fountain, hallway A139, south wall, west end, left side	ND	-	-	1
	042717.370A.A139DF.02	Drinking fountain, hallway A139, south wall, west end, right side	ND	-	-	1
	042717.370A.A139DF.03	Drinking fountain, hallway A139, south wall, west end, bottle	ND	-	-	1
	042717.370A.A139DF.04	Drinking fountain, hallway A139, south wall, east end, left side	ND	-	-	1
	042717.370A.A139DF.05	Drinking fountain, hallway A139, south wall, east end, right side	ND	-	-	1
	042717.370A.A208SK.01	Sink, room A208	ND	-	-	1
	042717.370A.A214SK.01	Sink, room A214	1	-	-	1
	042717.370A.A218SK.01	Sink, room A218	0.57	-	-	1
	042717.370A.A223DF.01	Drinking fountain, hallway A223, east wall, north end, left side	ND	-	-	1
	042717.370A.A223DF.02	Drinking fountain, hallway A223, east wall, north end, right side	ND	-	-	1
	042717.370A.A223SK.01	Sink, room A223	1.2	-	-	1
	042717.370A.A225FSK.01	Sink, room A225F	2.6	-	-	1
	042717.370A.A225ISK.01	Sink, room A225I	0.84	-	-	1
	042717.370A.A234DF.01	Drinking fountain, hallway A234, north wall, west end, left side	ND	-	-	1
	042717.370A.A234DF.02	Drinking fountain, hallway A234, north wall, west end, right side	ND	-	-	1
	042717.370A.A234DF.03	Drinking fountain, hallway A234, north wall, west end, bottle	ND	-	-	1
	042717.370A.A238DF.01	Drinking fountain, hallway A238, south wall, west end, left side	ND	-	-	1
	042717.370A.A238DF.02	Drinking fountain, hallway A238, south wall, west end, right side	ND	-	-	1
	042717.370A.A238DF.03	Drinking fountain, hallway A238, south wall, east end, left side	ND	-	-	1
	042717.370A.A238DF.04	Drinking fountain, hallway A238, south wall, east end, right side	ND	-	-	1
	042717.370A.B103SK.01	Sink, room B103	0.73	-	-	1
	042717.370A.B203SK.01	Sink, room B203	2.3	-	-	1
	042717.370A.D104SK.01	Sink, room D104	2.6	-	-	1
	042717.370A.D204SK.01	Sink, room D204	ND	-	-	1
	042717.370A.E205SK.01	Sink, room E205, west wall, right side SK	0.6	-	-	1
	042717.370A.E205SK.02	Sink, room E205, west wall, left side SK	2.4	-	-	1
	042717.370A.E205SK.03	Sink, room E205, south wall, left side SK	0.65	-	-	1
	042717.370A.E205SK.04	Sink, room E205, south wall, right side SK	2.1	-	-	1
	042717.370A.E205SK.05	Sink, room E205, east wall, right side SK	ND	-	-	1
	042717.370A.E205SK.06	Sink, room E205, east wall, middle SK	1.5	-	-	1
	042717.370A.E205SK.07	Sink, room E205, east wall, left side SK	0.72	-	-	1
	042717.370A.E205SK.08	Sink, room E205, island SK	0.85	-	-	1
	042717.370A.E206SK.01	Sink, room E206	2.7	-	-	1
	042717.370A.F201SK.01	Sink, room F201	1.8	-	-	1
	042717.370A.F211SK.01	Sink, room F211, north wall, left side SK	0.51	-	-	1
	042717.370A.F211SK.02	Sink, room F211, north wall, right side SK	0.62	-	-	1
	042717.370A.F211SK.03	Sink, room F211, east wall, left side SK	0.74	-	-	1
	042717.370A.F211SK.04	Sink, room F211, east wall, right side SK	0.71	-	-	1
	042717.370A.F213SK.01	Sink, room F213, north wall, right side SK	ND	-	-	1
	042717.370A.F213SK.02	Sink, room F213, north wall, left side SK	0.7	-	-	1
	042717.370A.F213SK.03	Sink, room F213, NW corner	ND	-	-	1
	042717.370A.F213SK.04	Sink, room F213, west wall, right side SK	ND	-	-	1
	042717.370A.F213SK.05	Sink, room F213, west wall, left side SK	0.56	-	-	1
	042717.370A.F215DF.01	Drinking fountain, room F215	ND	-	-	1
	042717.370A.F217DF.01	Drinking fountain, room F217	ND	-	-	1
	042717.370A.G104DF.01	Drinking fountain, room G104	ND	-	-	1
	042717.370A.G111DF.01	Drinking fountain, room G111	2.4	-	-	1
	042717.370A.G112SK.01	Sink, room G112	0.6	-	-	1
	042717.370A.G115DF.01	Drinking fountain, room G115	ND	-	-	1
	042717.370A.G121DF.01	Drinking fountain, room G121	ND	-	-	1
	042717.370A.G130DF.01	Drinking fountain, hallway G130, west wall, left side DF	ND	-	-	1
	042717.370A.G130DF.02	Drinking fountain, hallway G130, west wall, right side DF	ND	-	-	1
	042717.370A.G211SK.01	Sink, room G211, west wall, south end	9.2	-	-	1

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Legacy HS**

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
Initial Sample	042717.370A.G211SK.02	Sink, room G211, middle of room, south side	0.82	-	-	1
	042717.370A.G211SK.03	Sink, room G211, west wall, outside doorway	ND	-	-	1
	042717.370A.G211SK.04	Sink, room G211, NW corner, left side SK	4.9	-	-	1
	042717.370A.G211SK.05	Sink, room G211, NW corner, right side SK	2.1	-	-	1
	042717.370A.G211SK.06	Sink, room G211, middle of room, north side, kitchen	69	Taken offline	-	1
	042717.370A.G211SK.07	Sink, room G211, east wall, north end	6.4	-	-	1
	042717.370A.G211SK.08	Sink, room G211, NE corner	1.1	-	-	1
Initial Sample Total						64

Resultados de las Muestras de Agua

Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

Action = Acción

Taken offline = Desconectado/a