

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Leroy Elementary

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
Initial Sample	011017.129A.10DF.01	Drinking fountain, room 10	2.6	-	-	1
	011017.129A.10SK.01	Sink, room 10	11	-	-	1
	011017.129A.110DF.01	Drinking fountain, long main hallway 110	ND	-	-	1
	011017.129A.110DF.02	Drinking fountain, short main hallway 110	2.2	-	-	1
	011017.129A.119ASK.01	Sink, room 119A	5.5	-	-	1
	011017.129A.119DF.01	Drinking fountain, room 119	2.9	-	-	1
	011017.129A.11DF.01	Drinking fountain, room 11	1.5	-	-	1
	011017.129A.11SK.01	Sink, room 11	7.7	-	-	1
	011017.129A.12DF.01	Drinking fountain, room 12	1.9	-	-	1
	011017.129A.12SK.01	Sink, room 12	11	-	-	1
	011017.129A.13DF.01	Drinking fountain, room 13	3.1	-	-	1
	011017.129A.13SK.01	Sink, room 13	10	-	-	1
	011017.129A.14DF.01	Drinking fountain, room 14	1.4	-	-	1
	011017.129A.14SK.01	Sink, room 14	4.9	-	-	1
	011017.129A.15DF.01	Drinking fountain, room 15	2.9	-	-	1
	011017.129A.15SK.01	Sink, room 15	2.8	-	-	1
	011017.129A.16DF.01	Drinking fountain, room 16	3.4	-	-	1
	011017.129A.16SK.01	Sink, room 16	6.8	-	-	1
	011017.129A.17DF.01	Drinking fountain, room 17	4	-	-	1
	011017.129A.17SK.01	Sink, room 17	13	-	-	1
	011017.129A.18DF.01	Drinking fountain, room 18	2.8	-	-	1
	011017.129A.18SK.01	Sink, room 18	3.6	-	-	1
	011017.129A.19DF.01	Drinking fountain, room 19	1.7	-	-	1
	011017.129A.19SK.01	Sink, room 19, Currently a 4th grade	18	Taken offline	-	1
	011017.129A.1DF.01	Drinking fountain, room 1	0.62	-	-	1
	011017.129A.1SK.01	Sink, room 1	5	-	-	1
	011017.129A.20DF.01	Drinking fountain, room 20	5.5	-	-	1
	011017.129A.20SK.01	Sink, room 20, Currently a 4th grade	15	Taken offline	-	1
	011017.129A.23SK.01	Sink, room 23, middle of room	1.5	-	-	1
	011017.129A.23SK.02	Sink, room 23, north wall	2.1	-	-	1
	011017.129A.23SK.03	Sink, room 23, NE corner	0.7	-	-	1
	011017.129A.23SK.04	Sink, room 23, middle of room on east side	0.68	-	-	1
	011017.129A.27SK.01	Sink, room 27	0.79	-	-	1
	011017.129A.2DF.01	Drinking fountain, room 2, next to SK.01	2.7	-	-	1
	011017.129A.2SK.01	Sink, room 2, NE corner, Currently a 1st grade	33	Taken offline	-	1
	011017.129A.2SK.02	Sink, room 2, SE corner	ND	-	-	1
	011017.129A.35SK.01	Sink, room 35	ND	-	-	1
	011017.129A.38SK.01	Sink, room 58	ND	-	-	1
	011017.129A.3CSK.01	Sink, room 3	3.5	-	-	1
	011017.129A.4DF.01	Drinking fountain, room 4, next to SK.01	2.3	-	-	1
	011017.129A.4SK.01	Sink, room 4, NE corner, Currently a 1st grade	23	Taken offline	-	1
	011017.129A.4SK.02	Sink, room 4, SE corner	1.6	-	-	1
	011017.129A.54DF.01	Drinking fountain, room 54	ND	-	-	1
	011017.129A.54SK.01	Sink, room 54	1.3	-	-	1
	011017.129A.57DF.01	Drinking fountain, room 57, next to SK.01	3.2	-	-	1
011017.129A.57DF.02	Drinking fountain, room 57, next to SK.02	ND	-	-	1	
011017.129A.57SK.01	Sink, room 57, NE corner	4.5	-	-	1	
011017.129A.57SK.02	Sink, room 57, SE corner	ND	-	-	1	
011017.129A.58DF.01	Drinking fountain, room 58, next to SK.01	7.4	-	-	1	
011017.129A.58DF.02	Drinking fountain, room 58, next to SK.02	1.2	-	-	1	
011017.129A.58SK.01	Sink, room 58, SW corner	2.7	-	-	1	
011017.129A.58SK.02	Sink, room 58, NW corner	ND	-	-	1	
011017.129A.59DF.01	Drinking fountain, room 59, next to SK.01	ND	-	-	1	
011017.129A.59DF.02	Drinking fountain, room 59, next to SK.02	ND	-	-	1	

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Leroy Elementary

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
	011017.129A.59SK.01	Sink, room 59, NW corner	3.5	-	-	1
	011017.129A.59SK.02	Sink, room 59, SW corner	1.7	-	-	1
	011017.129A.5DF.01	Drinking fountain, room 5	1	-	-	1
	011017.129A.5SK.01	Sink, room 5	4.6	-	-	1
	011017.129A.60DF.01	Drinking fountain, room 60, next to SK.01	ND	-	-	1
	011017.129A.60DF.02	Drinking fountain, room 60, next to SK.02	ND	-	-	1
	011017.129A.60SK.01	Sink, room 60, NE corner	3.7	-	-	1
	011017.129A.60SK.02	Sink, room 60, SE corner	1.6	-	-	1
	011017.129A.61SK.01	Sink, room 61	1.4	-	-	1
	011017.129A.68DF.01	Drinking fountain, hallway 68, SW end	ND	-	-	1
	011017.129A.68DF.02	Drinking fountain, hallway 68, SW end	0.59	-	-	1
	011017.129A.6DF.01	Drinking fountain, room 6	1.3	-	-	1
	011017.129A.6SK.01	Sink, room 6	10	-	-	1
	011017.129A.8SK.01	Sink, room 8	1.2	-	-	1
	011017.129A.9DF.01	Drinking fountain, room 9	4.6	-	-	1
	011017.129A.9SK.01	Sink, room 9	6	-	-	1
Initial Sample Total						70
Resample - 1	012717.129A.19SK.01	Sink, room 19, Currently a 4th grade	22	Pending	-	1
	012717.129A.20SK.01	Sink, room 20, Currently a 4th grade	37	Pending	-	1
	012717.129A.2SK.01	Sink, room 2, NE corner, Currently a 1st grade	6.8	Back in Service	2/1/2017	1
	012717.129A.4SK.01	Sink, room 4, NE corner, Currently a 1st grade	6.9	Back in Service	2/1/2017	1
Resample - 1 Total						4
Resample - 2	021417.129A.19SK.01	Sink, room 19, Currently a 4th grade	0.87	Back in Service	3/1/2017	1
	021417.129A.20SK.01	Sink, room 20, Currently a 4th grade	1.9	Back in Service	3/1/2017	1
Resample - 2 Total						2