

## Water Sampling Results

### Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above  
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Malley Drive ES**

Sample Type	Sample ID	Sample Description	Lead Result	Action Taken	Back in Service	Sample Count
			in PPB		Date	
Initial Sample	011117.132A.10DF.01	Drinking fountain, room 10	1.7	-	-	1
	011117.132A.10SK.01	Sink, room 10	1.7	-	-	1
	011117.132A.11DF.01	Drinking fountain, room 11	ND	-	-	1
	011117.132A.11SK.01	Sink, room 11	0.57	-	-	1
	011117.132A.12DF.01	Drinking fountain, room 12	ND	-	-	1
	011117.132A.12SK.01	Sink, room 12	3.4	-	-	1
	011117.132A.13SK.01	Sink, room 13	1.3	-	-	1
	011117.132A.14SK.01	Sink, room 14	4.1	-	-	1
	011117.132A.15DF.01	Drinking fountain, room 15	2.1	-	-	1
	011117.132A.15SK.01	Sink, room 15	14	-	-	1
	011117.132A.16DF.01	Drinking fountain, room 16	1.6	-	-	1
	011117.132A.16SK.01	Sink, room 16	4.5	-	-	1
	011117.132A.17DF.01	Drinking fountain, room 17	1.4	-	-	1
	011117.132A.17SK.01	Sink, room 17, currently 3rd grade	18	Taken offline	-	1
	011117.132A.18DF.01	Drinking fountain, room 18	1.1	-	-	1
	011117.132A.18SK.01	Sink, room 18	3.9	-	-	1
	011117.132A.19DF.01	Drinking fountain, room 19	1	-	-	1
	011117.132A.19SK.01	Sink, room 19	3.5	-	-	1
	011117.132A.20DF.01	Drinking fountain, room 20	1.9	-	-	1
	011117.132A.20SK.01	Sink, room 20	10	-	-	1
	011117.132A.21DF.01	Drinking fountain, room 21	1.5	-	-	1
	011117.132A.21SK.01	Sink, room 21	5.6	-	-	1
	011117.132A.22DF.01	Drinking fountain, room 22	2.1	-	-	1
	011117.132A.22SK.01	Sink, room 22	7	-	-	1
	011117.132A.23DF.01	Drinking fountain, room 23	2.6	-	-	1
	011117.132A.23SK.01	Sink, room 23, currently 4th grade	420	Taken offline	-	1
	011117.132A.24DF.01	Drinking fountain, room 24	1.7	-	-	1
	011117.132A.24SK.01	Sink, room 24, currently 4th grade	80	Taken offline	-	1
	011117.132A.29DF.01	Drinking fountain, room 29, south DF	0.81	-	-	1
	011117.132A.29DF.02	Drinking fountain, room 29, north DF	ND	-	-	1
	011117.132A.30SK.01	Sink, room 30, middle island	0.95	-	-	1
	011117.132A.30SK.02	Sink, room 30, south wall	5.2	-	-	1
	011117.132A.30SK.03	Sink, room 30, outside restroom door	1.6	-	-	1
	011117.132A.30SK.04	Sink, room 30, north wall	0.73	-	-	1
	011117.132A.30SK.05	Sink, room 30, middle of room on north side	1.9	-	-	1
	011117.132A.35SK.01	Sink, room 35	1.5	-	-	1
	011117.132A.38SK.01	Sink, room 38	0.5	-	-	1
	011117.132A.44SK.01	Sink, room 44	0.69	-	-	1
	011117.132A.4CSK.01	Sink, room 4C	0.89	-	-	1
	011117.132A.50SK.01	Sink, room 50	0.56	-	-	1
	011117.132A.51SK.01	Sink, room 51	ND	-	-	1
	011117.132A.56DF.01	Drinking fountain, room 56, next to SK.01	ND	-	-	1
	011117.132A.56DF.02	Drinking fountain, room 56, next to SK.02	ND	-	-	1
	011117.132A.56SK.01	Sink, room 56, NE sink	0.92	-	-	1
	011117.132A.56SK.02	Sink, room 56, NW sink	0.99	-	-	1
	011117.132A.57DF.01	Drinking fountain, room 57, next to SK.01	ND	-	-	1
	011117.132A.57DF.02	Drinking fountain, room 57, next to SK.02	ND	-	-	1
	011117.132A.57SK.01	Sink, room 57, SE sink	0.77	-	-	1
	011117.132A.57SK.02	Sink, room 57, SW sink	0.62	-	-	1
	011117.132A.59DF.01	Drinking fountain, room 59, next to SK.01	ND	-	-	1
	011117.132A.59DF.02	Drinking fountain, room 59, next to SK.02	ND	-	-	1
	011117.132A.59SK.01	Sink, room 59, NE sink	0.78	-	-	1
	011117.132A.59SK.02	Sink, room 59, NW sink	0.93	-	-	1
	011117.132A.60DF.01	Drinking fountain, room 60, next to SK.01	ND	-	-	1
	011117.132A.60DF.02	Drinking fountain, room 60, next to SK.02	ND	-	-	1

## Water Sampling Results

**Report Legend:**

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

**School Name Malley Drive ES**

Sample Type	Sample ID	Sample Description	Lead Result	Action Taken	Back in Service	Sample Count
			in PPB		Date	
Initial Sample	011117.132A.60SK.01	Sink, room 60, SE sink	1.1	-	-	1
	011117.132A.60SK.02	Sink, room 60, SW sink	0.6	-	-	1
	011117.132A.6DF.01	Drinking fountain, room 6	1.5	-	-	1
	011117.132A.6SK.01	Sink, room 6	2.2	-	-	1
	011117.132A.73DF.01	Drinking fountain, hallway 73, west end, south DF	ND	-	-	1
	011117.132A.73DF.02	Drinking fountain, hallway 73, west end, north DF	ND	-	-	1
	011117.132A.7DF.01	Drinking fountain, room 7	1.4	-	-	1
	011117.132A.7SK.01	Sink, room 7	2.8	-	-	1
	011117.132A.8DF.01	Drinking fountain, room 8	1.4	-	-	1
	011117.132A.8SK.01	Sink, room 8	1.6	-	-	1
	011117.132A.9DF.01	Drinking fountain, room 9	1.2	-	-	1
	011117.132A.9SK.01	Sink, room 9	1.4	-	-	1
	011117.132A.H1DF.01	Drinking fountain, hallway H1, NE end, east DF	1.1	-	-	1
	011117.132A.H1DF.02	Drinking fountain, hallway H1, NE end, west DF	0.88	-	-	1
<b>Initial Sample Total</b>						<b>69</b>
Resample - 1	031517.132A.17SK.01	Sink, room 17, currently 3rd grade	1.6	Back in Service	3/28/2017	1
	031517.132A.23SK.01	Sink, room 23, currently 4th grade	2.4	Back in Service	3/28/2017	1
	031517.132A.24SK.01	Sink, room 24, currently 4th grade	1.2	Back in Service	3/28/2017	1
<b>Resample - 1 Total</b>						<b>3</b>