

## Water Sampling Results

### Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above  
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

**School Name** Rocky Mountain ES

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
Initial Sample	021417.149A.A100DF.01	Drinking fountain, corridor A100, east wall, left side DF	ND	-	-	1
	021417.149A.A100DF.02	Drinking fountain, corridor A100, east wall, right side DF	ND	-	-	1
	021417.149A.A102SK.01	Sink, room A102	ND	-	-	1
	021417.149A.A109SK.01	Sink, room A109	1.3	-	-	1
	021417.149A.B102DF.01	Drinking fountain, room B102, attached to sink	1.2	-	-	1
	021417.149A.B102SK.01	Sink, room B102	8.8	-	-	1
	021417.149A.B102SK.02	Sink, room B102, NE corner	3.6	-	-	1
	021417.149A.B106SK.01	Sink, room B106	4.5	-	-	1
	021417.149A.B108DF.01	Drinking fountain, room B108, attached to sink	1.6	-	-	1
	021417.149A.B108SK.01	Sink, room B108	1.4	-	-	1
	021417.149A.B108SK.02	Sink, room B108, NE corner	1.3	-	-	1
	021417.149A.B110DF.01	Drinking fountain, room B110, attached to sink	0.53	-	-	1
	021417.149A.B110SK.01	Sink, room B110	3.5	-	-	1
	021417.149A.B111SK.01	Sink, room B111	6.2	-	-	1
	021417.149A.B112DF.01	Drinking fountain, room B112, attached to sink	1.1	-	-	1
	021417.149A.B112SK.01	Sink, room B112	6.7	-	-	1
	021417.149A.B114DF.01	Drinking fountain, room B114, attached to sink	0.78	-	-	1
	021417.149A.B114SK.01	Sink, room B114	1.5	-	-	1
	021417.149A.B115DF.01	Drinking fountain, room B115, attached to sink	0.58	-	-	1
	021417.149A.B115SK.01	Sink, room B115	3.9	-	-	1
	021417.149A.B116DF.01	Drinking fountain, room B116, attached to sink	0.89	-	-	1
	021417.149A.B116SK.01	Sink, room B116	1.2	-	-	1
	021417.149A.B119DF.01	Drinking fountain, room B119, attached to sink	1.1	-	-	1
	021417.149A.B119SK.01	Sink, room B119	6.2	-	-	1
	021417.149A.B122DF.01	Drinking fountain, room B122, attached to sink	1.2	-	-	1
	021417.149A.B122SK.01	Sink, room B122	1.2	-	-	1
	021417.149A.B124DF.01	Drinking fountain, room B124, attached to sink	1.5	-	-	1
	021417.149A.B124SK.01	Sink, room B124	2.2	-	-	1
	021417.149A.B126DF.01	Drinking fountain, room B126, attached to sink	0.97	-	-	1
	021417.149A.B126SK.01	Sink, room B126	4.5	-	-	1
	021417.149A.B128DF.01	Drinking fountain, room B128, attached to sink	ND	-	-	1
	021417.149A.B128SK.01	Sink, room B128	ND	-	-	1
	021417.149A.C104SK.01	Sink, room C104	3.3	-	-	1
	021417.149A.C105SK.01	Sink, room C105, currently the Dark Room	110	Taken offline	-	1
	021417.149A.C106SK.01	Sink, room C106	3.1	-	-	1
	021417.149A.C107SK.01	Sink, room C107	3.6	-	-	1
	021417.149A.C108DF.01	Drinking fountain, room C108, attached to sink	0.94	-	-	1
	021417.149A.C108SK.01	Sink, room C108	2.3	-	-	1
	021417.149A.C110DF.01	Drinking fountain, room C110, attached to sink	0.96	-	-	1
	021417.149A.C110SK.01	Sink, room C110	3.6	-	-	1
	021417.149A.C118DF.01	Drinking fountain, room C118, attached to sink	0.64	-	-	1
	021417.149A.C118SK.01	Sink, room C118	ND	-	-	1
	021417.149A.C119SK.01	Sink, room C119	2.4	-	-	1
	021417.149A.C120DF.01	Drinking fountain, room C120, attached to sink	0.8	-	-	1
	021417.149A.C120SK.01	Sink, room C120	4.6	-	-	1
	021417.149A.C122DF.01	Drinking fountain, room C122, attached to sink	0.55	-	-	1
	021417.149A.C122SK.01	Sink, room C122	2.5	-	-	1
021417.149A.C124DF.01	Drinking fountain, room C124, attached to sink	0.78	-	-	1	
021417.149A.C124SK.01	Sink, room C124	5.3	-	-	1	
021417.149A.C124SK.02	Sink, room C124, SW corner	1.4	-	-	1	
021417.149A.C127SK.01	Sink, room C127	0.51	-	-	1	
021417.149A.C128SK.01	Sink, room C128	1.7	-	-	1	
021417.149A.C130DF.01	Drinking fountain, room C130, attached to sink	1.1	-	-	1	
021417.149A.C130SK.01	Sink, room C130	2.3	-	-	1	
021417.149A.C130SK.02	Sink, room C130, NW corner	0.62	-	-	1	
021417.149A.D102DF.01	Drinking fountain, room D102, attached to sink	0.57	-	-	1	
021417.149A.D102SK.01	Sink, room D102	2.8	-	-	1	

## Water Sampling Results

### Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above  
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Rocky Mountain ES**

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
	021417.149A.D104DF.01	Drinking fountain, room D104, attached to sink	2.1	-	-	1
	021417.149A.D104SK.01	Sink, room D104	3.6	-	-	1
	021417.149A.D104SK.02	Sink, room D104, NW corner	ND	-	-	1
	021417.149A.D106SK.01	Sink, room D106	14	-	-	1
	021417.149A.D108DF.01	Drinking fountain, room D108, attached to sink	ND	-	-	1
	021417.149A.D108SK.01	Sink, room D108	9.8	-	-	1
	021417.149A.D108SK.02	Sink, room D108, SW corner	0.65	-	-	1
	021417.149A.D110DF.01	Drinking fountain, room D110, attached to sink	ND	-	-	1
	021417.149A.D110SK.01	Sink, room D110	3.3	-	-	1
	021417.149A.D112DF.01	Drinking fountain, room D112, attached to sink	0.71	-	-	1
	021417.149A.D112SK.01	Sink, room D112	3.4	-	-	1
	021417.149A.D114DF.01	Drinking fountain, room D114, attached to sink	ND	-	-	1
	021417.149A.D114SK.01	Sink, room D114	1.9	-	-	1
	021417.149A.E110SK.01	Sink, room E110	2	-	-	1
	021417.149A.E115DF.01	Drinking fountain, room E115	ND	-	-	1
	021417.149A.F101SK.01	Sink, room F101	ND	-	-	1
	021417.149A.F110SK.01	Sink, room F110, NE corner	2.2	-	-	1
	021417.149A.F110SK.02	Sink, room F110, south wall, east sink	7	-	-	1
	021417.149A.F110SK.03	Sink, room F110, south wall, middle sink	1.2	-	-	1
	021417.149A.F110SK.04	Sink, room F110, south wall, SW corner	6.1	-	-	1
	021417.149A.F117DF.01	Drinking fountain, room F117, attached to sink	ND	-	-	1
	021417.149A.F117SK.01	Sink, room F117	4.8	-	-	1
<b>Initial Sample Total</b>						<b>79</b>
Retest Sample - 1	041217.149A.C105SK.01	Sink, room C105, currently the Dark Room	6.8	Back in service	4/27/2017	1
<b>Retest Sample - 1 Total</b>						<b>1</b>