

## Water Sampling Results

### Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Rocky Top MS**

Sample Type	Sample ID	Sample Description	Lead Result		Action Taken	Back in Service Date	Sample Count	
			in PPB					
Initial Sample	032217.282A.200DF.01	Drinking fountain, corridor 200, west wall, middle, left side	ND		-	-	1	
	032217.282A.200DF.02	Drinking fountain, corridor 200, west wall, middle, right side	ND		-	-	1	
	032217.282A.200DF.03	Drinking fountain, corridor 200, west wall, north end, left side	ND		-	-	1	
	032217.282A.200DF.04	Drinking fountain, corridor 200, west wall, north end, right side	ND		-	-	1	
	032217.282A.300DF.01	Drinking fountain, corridor 300, west wall, left side DF	ND		-	-	1	
	032217.282A.300DF.02	Drinking fountain, corridor 300, west wall, right side DF	ND		-	-	1	
	032217.282A.300DF.03	Drinking fountain, corridor 300, west wall, bottle fill station	ND		-	-	1	
	032217.282A.500DF.01	Drinking fountain, corridor 500, west wall, middle, left side	ND		-	-	1	
	032217.282A.500DF.02	Drinking fountain, corridor 500, west wall, middle, right side	ND		-	-	1	
	032217.282A.500DF.03	Drinking fountain, corridor 500, west wall, middle, bottle fill station	ND		-	-	1	
	032217.282A.500DF.04	Drinking fountain, corridor 500, west wall, north end, right side	ND		-	-	1	
	032217.282A.500DF.05	Drinking fountain, corridor 500, west wall, north end, right side	ND		-	-	1	
	032217.282A.A106SK.01	Sink, room A106		1.9		-	-	1
	032217.282A.A107SK.01	Sink, room A107		0.73		-	-	1
	032217.282A.A206SK.01	Sink, room A206		ND		-	-	1
	032217.282A.A207SK.01	Sink, room A207		0.92		-	-	1
	032217.282A.B103SK.01	Sink, room B103, library resource room		220	Taken offline	-	-	1
	032217.282A.B107SK.01	Sink, room B107		0.54		-	-	1
	032217.282A.B109SK.01	Sink, room B109		0.55		-	-	1
	032217.282A.C106SK.01	Sink, room C106		0.51		-	-	1
	032217.282A.C107SK.01	Sink, room C107		0.5		-	-	1
	032217.282A.C200SK.01	Sink, room C200, SW corner		ND		-	-	1
	032217.282A.C200SK.02	Sink, room C200, SE corner		0.7		-	-	1
	032217.282A.C206SK.01	Sink, room C206		2.9		-	-	1
	032217.282A.C207SK.02	Sink, room C207		0.59		-	-	1
	032217.282A.D106SK.01	Sink, room D106		1.3		-	-	1
	032217.282A.D121DF.01	Drinking fountain, room D121, south wall		ND		-	-	1
	032217.282A.D121DF.02	Drinking fountain, room D121, south wall, bottle fill station		ND		-	-	1
	032217.282A.D121SK.01	Sink, room D121		ND		-	-	1
	032217.282A.D123SK.01	Sink, room D123		ND		-	-	1
	032217.282A.D139SK.01	Sink, room D139		ND		-	-	1
	032217.282A.D200SK.01	Sink, room D200, west wall, north end		ND		-	-	1
	032217.282A.D200SK.02	Sink, room D200, west wall, south end		0.55		-	-	1
	032217.282A.D204SK.01	Sink, room D204		3.3		-	-	1
	032217.282A.D208SK.01	Sink, room D208, east wall, south end		0.78		-	-	1
	032217.282A.D208SK.02	Sink, room D208, east wall, middle		1		-	-	1
	032217.282A.D208SK.03	Sink, room D208, east wall, north end		3.2		-	-	1
	032217.282A.D211SK.01	Sink, room D211, east wall		0.96		-	-	1
	032217.282A.D211SK.02	Sink, room D211, SE corner, currently an art classroom		20	Taken offline	-	-	1
	032217.282A.D212SK.01	Sink, room D212		0.51		-	-	1
	032217.282A.E100DF.01	Drinking fountain, room E100, north wall, west end, right side		ND		-	-	1
	032217.282A.E100DF.02	Drinking fountain, room E100, north wall, west end, left side		ND		-	-	1
	032217.282A.E100DF.03	Drinking fountain, room E100, north wall, east end		ND		-	-	1
	032217.282A.E106SK.01	Sink, room E106		2		-	-	1
	032217.282A.E107DF.01	Drinking fountain, room E107, SW corner, left side DF		ND		-	-	1
	032217.282A.E107DF.02	Drinking fountain, room E107, SW corner, right side DF		0.54		-	-	1
	032217.282A.E112SK.01	Sink, room E112		2.4		-	-	1
	032217.282A.E113DF.01	Drinking fountain, room E113, east wall, left side DF		ND		-	-	1
	032217.282A.E113DF.02	Drinking fountain, room E113, east wall, right side DF		ND		-	-	1
	032217.282A.F104SK.01	Sink, room F104, NE corner		1.8		-	-	1
032217.282A.F104SK.02	Sink, room F104, NW corner		0.59		-	-	1	
032217.282A.F104SK.03	Sink, room F104, west wall		1.4		-	-	1	
032217.282A.F104SK.04	Sink, room F104, SW corner		ND		-	-	1	
032217.282A.F104SK.05	Sink, room F104, south wall		1.6		-	-	1	
032217.282A.F104SK.06	Sink, room F104, SE corner		4.5		-	-	1	

## Water Sampling Results

**Report Legend:**

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

**School Name Rocky Top MS**

<u>Sample Type</u>	<u>Sample ID</u>	<u>Sample Description</u>	<u>Lead Result</u> <u>in</u> <u>PPB</u>	<u>Action Taken</u>	<u>Back in Service</u> <u>Date</u>	<u>Sample</u> <u>Count</u>
Initial Sample	032217.282A.F105SK.01	Sink, room F105	3.2	-	-	1
	032217.282A.F115DF.01	Drinking fountain, room F115	ND	-	-	1
	032217.282A.F122DF.01	Drinking fountain, room F122	ND	-	-	1
	032217.282A.F122SK.01	Sink, room F122	1.4	-	-	1
<b>Initial Sample Total</b>						<b>59</b>

# Resultados de las Muestras de Agua

## Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

### Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

### Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

### Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

### Action = Acción

Taken offline = Desconectado/a