

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Silver Hills MS**

Sample Type	Sample ID	Sample Description	Lead Result	Action Taken	Back in Service	Sample Count
			in PPB		Date	
Initial Sample	032317.283A.200DF.01	Drinking fountain, corridor 200, west wall, left side DF	ND	-	-	1
	032317.283A.200DF.02	Drinking fountain, corridor 200, west wall, right side DF	ND	-	-	1
	032317.283A.200DF.03	Drinking fountain, corridor 200, west wall, south end, left side DF	ND	-	-	1
	032317.283A.200DF.04	Drinking fountain, corridor 200, west wall, south end, right side DF	ND	-	-	1
	032317.283A.300DF.01	Drinking fountain, corridor 300, west wall, left side DF	ND	-	-	1
	032317.283A.300DF.02	Drinking fountain, corridor 300, west wall, right side DF	ND	-	-	1
	032317.283A.500DF.01	Drinking fountain, corridor 500, west wall, middle, left side DF	ND	-	-	1
	032317.283A.500DF.02	Drinking fountain, corridor 500, west wall, middle, right side DF	ND	-	-	1
	032317.283A.500DF.03	Drinking fountain, corridor 500, west wall, north end, left side DF	ND	-	-	1
	032317.283A.500DF.04	Drinking fountain, corridor 500, west wall, north end, right side DF	ND	-	-	1
	032317.283A.A100SK.01	Sink, room A100	ND	-	-	1
	032317.283A.A106SK.01	Sink, room A106	ND	-	-	1
	032317.283A.A107SK.01	Sink, room A107	ND	-	-	1
	032317.283A.A200SK.01	Sink, room A200, north wall	0.79	-	-	1
	032317.283A.A200SK.02	Sink, room A200, SW corner	ND	-	-	1
	032317.283A.A200SK.03	Sink, room A200, SE corner	ND	-	-	1
	032317.283A.A206SK.01	Sink, room A206	ND	-	-	1
	032317.283A.A207SK.01	Sink, room A207	ND	-	-	1
	032317.283A.B107SK.01	Sink, room B107	ND	-	-	1
	032317.283A.B109SK.01	Sink, room B109	1.4	-	-	1
	032317.283A.C100SK.01	Sink, room C100, north wall	1.1	-	-	1
	032317.283A.C100SK.02	Sink, room C100, SW corner	ND	-	-	1
	032317.283A.C100SK.03	Sink, room C100, SE corner	0.5	-	-	1
	032317.283A.C106SK.01	Sink, room C106	0.62	-	-	1
	032317.283A.C107SK.01	Sink, room C107	ND	-	-	1
	032317.283A.C204SK.01	Sink, room D204, north wall	0.8	-	-	1
	032317.283A.C204SK.02	Sink, room D204, NE corner	1	-	-	1
	032317.283A.C204SK.03	Sink, room D204, SE corner	ND	-	-	1
	032317.283A.C204SK.04	Sink, room D204, SW corner	ND	-	-	1
	032317.283A.C206SK.01	Sink, room C206	0.6	-	-	1
	032317.283A.C207SK.01	Sink, room C207	0.58	-	-	1
	032317.283A.D106SK.01	Sink, room D106	ND	-	-	1
	032317.283A.D121SK.01	Sink, room D121	ND	-	-	1
	032317.283A.D123SK.01	Sink, room D123	ND	-	-	1
	032317.283A.D139SK.01	Sink, room D139	ND	-	-	1
	032317.283A.D200SK.01	Sink, room D200, north wall	0.51	-	-	1
	032317.283A.D200SK.02	Sink, room D200, west wall, north end	0.69	-	-	1
	032317.283A.D200SK.03	Sink, room D200, west wall, south end	0.86	-	-	1
	032317.283A.D200SK.04	Sink, room D200, south wall	0.62	-	-	1
	032317.283A.D204SK.01	Sink, room D204	1.4	-	-	1
	032317.283A.D208SK.01	Sink, room D208, east wall, south end	0.54	-	-	1
	032317.283A.D208SK.02	Sink, room D208, east wall, middle	0.54	-	-	1
	032317.283A.D208SK.03	Sink, room D208, east wall, north end	0.9	-	-	1
	032317.283A.D211SK.01	Sink, room D211, east wall	3.1	-	-	1
	032317.283A.D211SK.02	Sink, room D211, SE corner	4.3	-	-	1
	032317.283A.D212SK.01	Sink, room D212	ND	-	-	1
	032317.283A.E100DF.01	Drinking fountain, room E100, north wall, west end, left side DF	ND	-	-	1
	032317.283A.E100DF.02	Drinking fountain, room E100, north wall, west end, right side DF	ND	-	-	1
	032317.283A.E100DF.03	Drinking fountain, room E100, north wall, east end	ND	-	-	1
	032317.283A.E106SK.01	Sink, room E106	1	-	-	1
032317.283A.E107DF.01	Drinking fountain, room E107, SW corner, left side DF	ND	-	-	1	
032317.283A.E107DF.02	Drinking fountain, room E107, SW corner, right side DF	ND	-	-	1	
032317.283A.E112SK.01	Sink, room E112	0.58	-	-	1	
032317.283A.E113DF.01	Drinking fountain, room E113, east wall, left side DF	ND	-	-	1	
032317.283A.E113DF.02	Drinking fountain, room E113, east wall, right side DF	ND	-	-	1	

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Silver Hills MS

<u>Sample Type</u>	<u>Sample ID</u>	<u>Sample Description</u>	<u>Lead Result</u> <u>in</u> <u>PPB</u>	<u>Action Taken</u>	<u>Back in Service</u> <u>Date</u>	<u>Sample</u> <u>Count</u>
Initial Sample	032317.283A.F100DF.01	Drinking fountain, room F100	ND	-	-	1
	032317.283A.F103SK.01	Sink, room F103, NW corner of island	ND	-	-	1
	032317.283A.F103SK.02	Sink, room F103, east wall	ND	-	-	1
	032317.283A.F103SK.03	Sink, room F103, SE corner	5	-	-	1
	032317.283A.F103SK.04	Sink, room F103, south end of island	0.51	-	-	1
	032317.283A.F103SK.05	Sink, room F103, NW corner by cafeteria	ND	-	-	1
	032317.283A.F105SK.01	Sink, room F105, east wall	0.95	-	-	1
	032317.283A.F115DF.01	Drinking fountain, room F105	ND	-	-	1
	032317.283A.F115SK.01	Sink, room F115	0.91	-	-	1
	032317.283A.F122DF.01	Sink, room F122	ND	-	-	1
Initial Sample Total						65

Resultados de las Muestras de Agua

Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

Action = Acción

Taken offline = Desconectado/a