

## Water Sampling Results

### Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above  
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

**School Name** Skyview ES

Sample ID	Sample Description	Lead Result in PPB	Action Taken
020717.151A.120DF.01	Drinking fountain, hallway 120, east wall, south sink	1.6 -	
020717.151A.120DF.02	Drinking fountain, hallway 120, east wall, north sink	0.83 -	
020717.151A.100SK.01	Sink, room 100	2.6 -	
020717.151A.101SK.01	Sink, room 101	0.68 -	
020717.151A.103SK.01	Sink, room 103	1.1 -	
020717.151A.102SK.01	Sink, room 102	0.78 -	
020717.151A.105BSK.01	Sink, room 105B	1.1 -	
020717.151A.106SK.01	Sink, room 106, south wall, middle of room	0.74 -	
020717.151A.106SK.02	Sink, room 106, south wall, west side	1.2 -	
020717.151A.106SK.03	Sink, room 106, west wall	ND	-
020717.151A.106SK.04	Sink, room 106, west wall	1.7 -	
020717.151A.107SK.01	Sink, room 107, NW corner	1.3 -	
020717.151A.107DF.01	Drinking fountain, room 107, NW corner, attached to sink	ND	-
020717.151A.107DF.02	Drinking fountain, room 107, NE corner	0.87 -	
020717.151A.108DF.01	Drinking fountain, room 108, west side, north wall, right side D	0.77 -	
020717.151A.108DF.02	Drinking fountain, room 108, west side, north wall, left side DF	0.55 -	
020717.151A.108ASK.01	Sink, room 108A	ND	-
020717.151A.ASK.01	Sink, room A	ND	-
020717.151A.ADF.01	Drinking fountain, room A, attached to sink	ND	-
020717.151A.BSK.01	Sink, room B	0.62 -	
020717.151A.BDF.01	Drinking fountain, room B, attached to sink	ND	-
020717.151A.AASK.01	Sink, room AA	ND	-
020717.151A.AADF.01	Drinking fountain, room AA, attached to sink	ND	-
020717.151A.ABSK.01	Sink, room AB, attached drinking fountain broken	4.5 -	
020717.151A.BBSK.01	Sink, room BB	ND	-
020717.151A.BBDF.01	Drinking fountain, room BB, attached to sink	ND	-
020717.151A.CSK.01	Sink, room C	ND	-
020717.151A.CDF.01	Drinking fountain, room C, attached to sink	ND	-
020717.151A.DSK.01	Sink, room D	ND	-
020717.151A.DDF.01	Drinking fountain, room D, attached to sink	ND	-
020717.151A.FSK.01	Sink, room F	ND	-
020717.151A.FDF.01	Drinking fountain, room F, attached to sink	ND	-
020717.151A.GSK.01	Sink, room G	ND	-
020717.151A.GDF.01	Drinking fountain, room G, attached to sink	0.71 -	
020717.151A.HSK.01	Sink, room H	ND	-
020717.151A.HDF.01	Drinking fountain, room H, attached to sink	5.2 -	
020717.151A.ISK.01	Sink, room I	0.53 -	
020717.151A.IDF.01	Drinking fountain, room I, attached to sink	0.7 -	
020717.151A.JSK.01	Sink, room J	1.3 -	
020717.151A.JDF.01	Drinking fountain, room J, attached to sink	ND	-
020717.151A.LSK.01	Sink, room L	0.71 -	
020717.151A.LDF.01	Drinking fountain, room L, attached to sink	0.72 -	

## Water Sampling Results

### Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above  
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

**School Name** Skyview ES

Sample ID	Sample Description	Lead Result in PPB	Action Taken
020717.151A.MSK.01	Sink, room M	0.66 -	
020717.151A.MDF.01	Drinking fountain, room M, attached to sink	0.9 -	
020717.151A.NSK.01	Sink, room N	2.1 -	
020717.151A.NDF.01	Drinking fountain, room N, attached to sink	0.55 -	
020717.151A.PSK.01	Sink, room P	1.9 -	
020717.151A.PDF.01	Drinking fountain, room P, attached to sink	0.79 -	
020717.151A.QSK.01	Sink, room Q	1 -	
020717.151A.QDF.01	Drinking fountain, room Q, attached to sink	ND	-
020717.151A.RSK.01	Sink, room R	ND	-
020717.151A.RDF.01	Drinking fountain, room R, attached to sink	0.56 -	
020717.151A.SSK.01	Sink, room S	1.5 -	
020717.151A.SDF.01	Drinking fountain, room S, attached to sink	ND	-
020717.151A.TSK.01	Sink, room T	2.4 -	
020717.151A.TDF.01	Drinking fountain, room T, attached to sink	0.7 -	
020717.151A.USK.01	Sink, room U	0.67 -	
020717.151A.UDF.01	Drinking fountain, room U, attached to sink	ND	-
020717.151A.VSK.01	Sink, room V	1.4 -	
020717.151A.VDF.01	Drinking fountain, room V, attached to sink	ND	-
020717.151A.WSK.01	Sink, room W	0.83 -	
020717.151A.WDF.01	Drinking fountain, room W, attached to sink	ND	-
020717.151A.XSK.01	Sink, room X	0.61 -	
020717.151A.XDF.01	Drinking fountain, room X, attached to sink	ND	-
020717.151A.YSK.01	Sink, room Y	0.84 -	
020717.151A.YDF.01	Drinking fountain, room Y, attached to sink	ND	-
020717.151A.ZSK.01	Sink, room Z	0.53 -	
020717.151A.ZDF.01	Drinking fountain, room Z, attached to sink	ND	-

# Resultados de las Muestras de Agua

## Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

### Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

### Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

### Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

### Action = Acción

Taken offline = Desconectado/a